

19 N.T.S. TOILET ROOM SIGNAGE



THE ABOVE SIGNS ARE DIAGRAMMATIC EXAMPLES ONLY – ACTUAL SIGNS MAY VARY SLIGHTLY DEPENDING ON SPECIFIC CONDITIONS, BUILDING STANDARDS AND MANUFACTURER

REQUIREMENTS FOR ALL SIGNS:
- NON-GLARE FINISH
- CHARACTERS TO CONTRAST w/ BACKGROUND

REQUIREMENTS FOR PERMANENT ROOM SIGNS ONLY:
- CHARACTERS RAISED 1/32"
- UPPER CASE SANS SERIF OR SIMPLE SERIF
- TEXT ACCOMPANIED BY GRADE 2 BRAILLE
- TEXT HEIGHT – 5/8" MIN. AND 2" MAX.
- MOUNTED ON WALL ADJACENT TO LATCH SIDE OF DOOR @ +60" TO ℄ OF SIGN MOUNTED 3" FROM DOOR EDGE

REQUIREMENTS FOR DIRECTIONAL AND INFORMATIONAL SIGNS:
- WIDTH TO HEIGHT RATIO BETWEEN 3:5 AND 1:1
- STROKE WIDTH TO HEIGHT RATIO BETWEEN 1:5 AND 1:10

17 N.T.S. TYPICAL INT. SIGNAGE



BRAILLE SYMBOLS: CALIFORNIA CONTRACTED GRADE 2 BRAILLE SHALL BE USED WHEREVER BRAILLE SYMBOLS ARE SPECIFICALLY REQUIRED IN OTHER PORTIONS OF THESE STANDARDS. DOTS SHALL BE $\frac{1}{10}$ INCH ON CENTERS IN EACH CELL WITH $\frac{1}{10}$ INCH SPACE BETWEEN CELLS. DOTS SHALL BE RAISED A MIN. OF $\frac{1}{40}$ INCH ABOVE THE BACKGROUND. BRAILLE SYMBOLS SHALL BE PLACED WITHIN $\frac{3}{8}$" MIN. TO $\frac{1}{2}$" MAX. BENEATH RAISED TACTILE LETTERS

15 N.T.S. TACTILE/BRAILLE SIGNAGE



BRAILLE SYMBOLS: CALIFORNIA CONTRACTED GRADE 2 BRAILLE SHALL BE USED WHEREVER BRAILLE SYMBOLS ARE SPECIFICALLY REQUIRED IN OTHER PORTIONS OF THESE STANDARDS. DOTS SHALL BE $\frac{1}{10}$ INCH ON CENTERS IN EACH CELL WITH $\frac{1}{10}$ INCH SPACE BETWEEN CELLS. DOTS SHALL BE RAISED A MIN. OF $\frac{1}{40}$ INCH ABOVE THE BACKGROUND. BRAILLE SYMBOLS SHALL BE PLACED WITHIN $\frac{3}{8}$" MIN. TO $\frac{1}{2}$" MAX. BENEATH RAISED TACTILE LETTERS

14 N.T.S. TACTILE EXIT SIGN



BRAILLE SYMBOLS: CALIFORNIA CONTRACTED GRADE 2 BRAILLE SHALL BE USED WHEREVER BRAILLE SYMBOLS ARE SPECIFICALLY REQUIRED IN OTHER PORTIONS OF THESE STANDARDS. DOTS SHALL BE $\frac{1}{10}$ INCH ON CENTERS IN EACH CELL WITH $\frac{1}{10}$ INCH SPACE BETWEEN CELLS. DOTS SHALL BE RAISED A MIN. OF $\frac{1}{40}$ INCH ABOVE THE BACKGROUND. BRAILLE SYMBOLS SHALL BE PLACED WITHIN $\frac{3}{8}$" MIN. TO $\frac{1}{2}$" MAX. BENEATH RAISED TACTILE LETTERS

P-INT-1

13 N.T.S. TACTILE STAIR SIGN



05720022

12 3/4" GUARD RAIL TO HANDRAIL



05720023

11 3" CONNECTION DETAIL

7 NOT USED

9 NOT USED



15440022

4 N.T.S. SINK DETAIL



10800012

3 3" GRAB BAR

WATER FOUNTAINS (DRINKING)

1. WATER FOUNTAINS SHALL BE LOCATED COMPLETELY WITHIN ALCOVES OR OTHERWISE POSITIONED SO AS NOT TO ENCROACH INTO PEDESTRIAN WAYS. THE ALCOVE IN WHICH THE WATER FOUNTAIN IS LOCATED SHALL BE NOT LESS THAN 32 INCHES IN WIDTH AND 18 INCHES IN DEPTH. THE DRINKING FOUNTAIN SHALL BE A BETWEEN 18 INCHES & 19 INCHES IN DEPTH AND THERE SHALL BE A CLEAR AND UNOBSTRUCTED SPACE UNDER THE DRINKING FOUNTAIN NOT LESS THAN 27 INCHES IN HEIGHT 30 INCHES IN WIDTH AND 8 INCHES IN DEPTH, THE DEPTH MEASUREMENT BEING TAKEN FROM THE FRONT EDGE OF THE FOUNTAIN. ADDITIONALLY, THERE SHALL BE TOE CLEARANCE 9 INCHES IN HEIGHT ABOVE THE FLOOR AND 17" FROM THE FRONT EDGE OF THE DRINKING FOUNTAIN. A SIDE APPROACH DRINKING FOUNTAIN IS NOT ACCEPTABLE.

2. THE BUBBLER SHALL BE MANUALLY ACTIVATED BY A CONTROL WHICH IS EASILY OPERATED BY A PERSON WITH DISABILITIES SUCH AS A HAND-OPERATED LEVER TYPE CONTROL LOCATED WITHIN 6 INCHES OF THE FRONT OF THE FOUNTAIN, A PUSH BAR CONTROL ALONG THE FRONT OF THE DRINKING FOUNTAIN, ETC. THE BUBBLER OUTLET ORIFICE SHALL BE LOCATED WITHIN 6 INCHES OF THE FRONT OF THE DRINKING FOUNTAIN AND SHALL BE WITHIN 36 INCHES OF THE FLOOR.



1544007

1 1/2" DF ALCOVE & NOTES

L Street Architects
Limited
1414 L Street
Modesto, California 95354
209-575-1415 209-575-4374 fax
www.lstreetarchitects.com

STATE OF CALIFORNIA · LICENSED ARCHITECT · ROBERT T. DeGROSE · C-8827 · RENEWAL 11/30/11

TENANT IMPROVEMENT FOR:
GRANITE REALTY
CORNERSTONE MALL
2000 BRIGGSMORE, SUITE I
MODESTO, CALIFORNIA

REVISIONS:
1 08/30/10 FIRE DEPT
2 09/27/10 FIRE DEPT

DRAWN: G. MEJIA
DATE: 7/13/2010
FILE: 995-A82
JOB: 51.995
PRINT DATE:

DETAILS

A8.2

© COPYRIGHT L STREET ARCHITECTS, INC. ALL RIGHTS RESERVED. ALL DRAWINGS AND DESIGNS CONTAINED IN THESE DRAWINGS ARE AND SHALL REMAIN THE PROPERTY OF L STREET ARCHITECTS, INC. AND SHALL NOT BE USED IN WHOLE OR IN PART FOR ANY PURPOSE WHATSOEVER WITHOUT THE WRITTEN PERMISSION OF L STREET ARCHITECTS, INC. ANY UNAUTHORIZED USE OF THESE DRAWINGS AND DESIGNS SHALL BE AT THE SOLE RISK AND RESPONSIBILITY OF THE USER. THESE DRAWINGS ARE NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ARCHITECT AND STAMPED "APPROVED FOR CONSTRUCTION".