

CITY OF ALGOMA
COUNTY OF KEWAUNEE
STATE OF WISCONSIN

COMMON COUNCIL
RESOLUTION NO 782 – 2016

A RESOLUTION AUTHORIZING THE REPAIR OF THE CITY OF ALGOMA
WASTEWATER TREATMENT PLANT PRIMARY CLARIFIER TANK

WHEREAS: The City of Algoma Wastewater Treatment Plant contains a primary clarifier tank which has been designated, in the recently approved Facilities Plan, for repairs to deteriorating concrete walls; and

WHEREAS: The deterioration of this clarifier tank has accelerated and caused two recent Sanitary Sewage Overflow (SSO) events; and

WHEREAS: The Wisconsin Department of Natural Resources has directed the City of Algoma to complete the necessary repairs to this clarifier tank by September 30, 2016 to avoid further SSO events; and

WHEREAS: Proposals have been requested from several vendors for necessary repair work;

NOW, THEREFORE BE IT RESOLVED: that the Common Council of the City of Algoma, Wisconsin hereby authorizes the Administrator – Clerk – Treasurer of the City of Algoma to contract for the repair of the Wastewater Treatment Plant primary clarifier tank, at a cost not to exceed \$40,000.00.

Adopted by Order of the Common Council of the City of Algoma, Wisconsin at a regular meeting thereof on the 6th day of September, 2016, by a vote of 8 for and 0 opposed.

Approved: Wayne R. Schmidt
Wayne R. Schmidt,
Mayor of the City of Algoma

Attest: Jeffrey L. Wiswell, Sr.
Jeffrey L. Wiswell, Sr.,
Administrator – Clerk – Treasurer of the City of Algoma