

---

**San Francisco Bay Regional Water Quality Control Board**

Date: March 21, 2016  
CIWQS File No: 246395  
Geotracker ID: L10009323371

Oyster Point Landfill  
City of South San Francisco  
Attn: Brian McMinn  
Email: [Brian.McMinn@ssf.net](mailto:Brian.McMinn@ssf.net)

**SUBJECT: Concurrence with Short-Term Flood Protection Plan, Oyster Point Landfill,  
City of South San Francisco**

Dear Mr. McMinn,

This letter concurs with your submittal of a Short-Term Flood Protection Plan (Plan) for the closed Oyster Point Landfill (landfill), dated February 26, 2016, and prepared by Tetra Tech BAS. This plan requires that you address and correct a violation of Waste Discharge Requirements Order No. R2-2000-0046 (Order). As stipulated in Specification 6 of the Order, the landfill's final cover system shall be graded and maintained to promote lateral runoff and prevent ponding and infiltration of water. The implementation of this Plan, along with a Long-Term Flood Protection Plan (due this summer) is intended to prevent ponding and flooding issues at the landfill.

The Plan requires re-grading of low spots at the landfill in manner that promotes drainage, repairing asphalt where needed, and retrofitting storm drain outlets by installing check valves to limit the backflow of Bay water.

If you have any questions, please contact Vic Pal of my staff at (510) 622-2403 or at [vpal@waterboards.ca.gov](mailto:vpal@waterboards.ca.gov).

Sincerely,

Bruce H. Wolfe  
Executive Officer

Cc: Greg Schirle (email: [gschirle@smcgov.org](mailto:gschirle@smcgov.org))  
Tim Moran (email: [timothy.moran@waterboards.ca.gov](mailto:timothy.moran@waterboards.ca.gov))  
Leslie Graves (email: [leslie.graves@waterboards.ca.gov](mailto:leslie.graves@waterboards.ca.gov))  
Sabrina Brennen (email: [sabrina@dfm.com](mailto:sabrina@dfm.com))  
Aaron Stessman (email: [aaron@cssenvironmental.com](mailto:aaron@cssenvironmental.com))