

LABORATORY TEST RESULTS FOR WATER SAMPLING OF LEAD LEVELS IN SCESD, OCTOBER 2017

SITE	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5
BORONDA DIA	ND*	ND	ND	1.1	1.9
BORONDA MEADOWS	ND	ND	ND	ND	ND
EL GABILAN	3.4	ND	ND	ND	ND
KAMMANN	ND	1.2	1.8	1.5	ND
LAUREL WOOD	1.8	1.1	ND	3.6	2.3
LINCOLN	ND	ND	ND	ND	2.7
LOMA VISTA	1.2	1.4	ND	2.5	
LOS PADRES	4.3	2.0	ND	ND	ND
MISSION PARK	1.2	5.2	ND	1.2	2.5
MONTEREY PARK	5.9	5.6	ND	ND	7.9
NATIVIDAD	2.3	3.3	2.0	5.4	ND
ROOSEVELT	ND	1.5	1.2	ND	ND
SHERWOOD	ND	ND	ND	1.0	ND
UNIVERSITY PARK	ND	1.2	2.1	1.3	ND

*ND= NONE DETECTED

1. STATE TEST LIMIT IS NOT MORE THAN 15 PARTS PER BILLION (PPB) OF LEAD FOR ANY HEALTH ISSUES.
2. ALL TESTING WAS COMPLETED OCT 13-20, 2017.
3. FIVE LOCATIONS WERE SELECTED AT EACH SITE SUCH THAT LONGER RUNS IN DIFFERENT AREAS OF EACH SCHOOL COULD BE EVALUATED TO PROVIDE THE MOST COMPREHENSIVE RESULTS.
4. SITES WERE TESTED AFTER REMAINING OUT OF USE ALL NIGHT AND PRIOR TO STAFF AND STUDENT ARRIVAL TO ENSURE THE HIGHEST POSSIBLE TEST RESULTS, CREATING A "WORST CASE" READING.