



# CHURCH SELF-INSPECTION FOR



Church \_\_\_\_\_ Date \_\_\_\_\_

Evaluators \_\_\_\_\_

	Yes	No	Description	Location	Recommendations Made	Date Corrected
<b>Section A</b>			<b>General</b>			
1. Written Disaster Plan (fire, earthquake, hurricane, tornado, violence, as applicable)						
2. Evacuation Plans posted						
3. Meeting room(s) occupant capacity posted						
4. Fire/emergency drills conducted annually during church service, or deacons meet on weeknight to perform dry-run fire drill						
5. Fire alarm system tested during drills						
6. Automatic sprinkler systems receive annual professional maintenance						
7. Fire extinguishers properly placed and current tag (Inspected and maintained annually by licensed technician)						
8. Church personnel visually inspect extinguishers monthly for adequate pressure or tampering						
9. Lighting adequate						
10. Good housekeeping						
11. Doors in good repair						
12. Panic hardware provided on exit doors (Deadbolts, chains, padlocks, and other devices <i>prohibited</i> unless approved by Authority Having Jurisdiction)						
13. Exit doors open in direction of exit travel						
14. Exit doors not blocked						
15. Building free from signs of roof or water pipe leaks and damage						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

16. Windows free of cracks and breaks						
17. Electrical wiring in good repair						
18. Large trash containers equipped with flip-top lids						
19. Oily rags and mops stored in metal containers						
20. GFCI Protection within 6' of sinks, etc., and in restrooms						
<b>Section B Walking and Working Surfaces</b>						
1. Floor surfaces, steps, etc. in good repair						
2. Uniform step heights on stairs						
3. Handrails at all steps and ramps						
4. Handrails properly secured						
5. Mid-rails on open sides of steps						
6. Rails, mid-rails and toe boards for balconies and overhead storage						
7. Floors free of tripping hazards and slippery surfaces						
8. "Wet Floor" signs used after mopping operations						
9. Carpets free of tears and wrinkles						
10. Floor openings properly guarded						
11. Proper lighting						
12. Full-length glass doors and windows properly marked with trim or decals						
<b>Section C Sanctuary</b>						
1. Lighting adequate						
2. Good housekeeping						
3. Pews secured to floor						
4. Microphone, speaker, video camera cables not presenting tripping hazard						
5. Doors in good repair						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

6. Exit doors open in direction of exit travel						
7. Smoke/fire doors kept closed						
8. All exit doors kept unlocked during occupancy						
9. Pianos, organs, other musical instruments not blocking exit passages or doors						
10. Panic hardware provided on exit doors (Deadbolts, chains, padlocks, and other devices <i>prohibited</i> unless approved by Authority Having Jurisdiction)						
11. Exit signs and lights in place and working properly						
12. Emergency lighting in place/tested/operating properly						
<b>Section D</b>						
<b>Baptismal Tanks</b>						
1. Wired microphones not used in or near baptismal tank unless wireless, or permanently mounted well outside reach of anyone in or near tank						
2. Stairs and walking surfaces coated with appropriate anti-slip material						
3. Baptismal tank filled day before baptism (filling process supervised until completed)						
4. Overflow protection provided						
5. Baptismal tank emptied immediately after church service						
6. Recheck performed to assure heater turned off						
7. Access door(s) to baptismal tank locked when tank not in use						
<b>Section E</b>						
<b>Mothers' Room</b>						
1. Cribs, changing tables, other equipment and conditions comply with Consumer Product Safety Commission guidelines (See <a href="http://www.cpsc.gov">www.cpsc.gov</a> for nursery safety information)						
2. Cribs, changing tables, other equipment inspected periodically for loose screws, bolts, etc. Inspections documented						
3. Changing table equipped with safety straps						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
4. Sign posted directing parents to “Always Use Safety Straps” and to “Never Leave Children Unattended Even When Straps Are In Use”						
5. All electrical outlets have protective covers installed						
<b>Section F</b>			<b>Corridors/Hallways</b>			
1. Corridors, exits and stairs free of storage or other obstructions						
2. All dead-end corridors properly labeled						
3. Exit signs and lights in place and working properly						
4. Emergency lighting in place/tested/operating properly						
5. Smoke/fire doors kept closed						
6. Fire extinguishers provided and tagged						
<b>Section G</b>			<b>Electrical/Mechanical Rooms</b>			
1. Multipurpose fire extinguisher provided						
2. Smoke/heat detectors provided						
3. 3-foot clearance maintained in front of and below electrical panels and equipment						
4. Main switches and shut-off valves labeled						
5. Room free of flammable and combustible storage						
6. Access door fire rated and self-closing						
7. Mechanical, electrical and air-conditioning systems inspected and serviced annually						
8. Good Housekeeping						
9. No holes in walls or ceilings (poke-throughs)						
<b>Section H</b>			<b>Kitchen</b>			
1. Hood and duct fire suppression with semi-annual service/ maintenance (tag current)						
2. Multi-purpose extinguisher provided/tagged						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

3. Vents/filters cleaned regularly – documented						
4. Smoke/heat detectors in good repair						
5. Food is not stored on floors						
6. Food in coolers/freezers covered						
7. Safety latches on all coolers/freezers						
8. Floors kept clean/free of spills						
9. All exits clearly marked with visible approved signs						
10. Portable signs used to indicate wet floors/hazards in kitchen and multi-purpose room						
11. Tables and chairs in good repair						
12. Unused folding chairs and tables stored in racks – not leaned against walls						
13. Hot water tanks secured and equipped with pressure relief valves						
14. Freezer At 0°F. (-17.8°C.)						
15. GFCI Protection within 6' of sinks, etc.						
<b>Section I</b>						
<b>Offices/Workrooms</b>						
1. Fire extinguisher available/tagged						
2. Electrical cords/plugs in good repair						
3. Aisles and lanes free of electrical cords, phone cords or other hazards						
4. No extension cords used (Limited power strip use acceptable)						
5. Finger guards on paper cutters, and cutting arm stays up when raised and released						
6. Good housekeeping in storage rooms						
7. Good ergonomic positioning of computer workstations						
8. Adequate access to equipment						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

<b>Section J</b>	<b>Classrooms</b>					
1.			Aisles and lanes free of electrical cords, phone cords or other hazards			
2.			Good housekeeping in storage closets			
3.			Finger guards on paper cutters, and cutting arm stays up when raised and released			
4.			Hazardous chemicals stored in locked cabinets or out of the reach of children			
5.			Audiovisual equipment strapped to wide-base, stable carts			
6.			GFCI Protection within 6' of sinks, etc.			
7.			No extension cords used (Limited power strip use acceptable)			
8.			Evacuation Plans posted in each classroom			
9.			Artwork, teaching materials and decorations cover less than 20% of wall area			
<b>Section K</b>	<b>Gymnasiums/Multi-Purpose Rooms</b>					
1.			Emergency lighting provided and maintained			
2.			Lighted exit signs provided and maintained			
3.			Fire extinguishers properly located/tagged			
4.			Access to exits unobstructed			
5.			Smoke/heat detectors over stage			
6.			Sprinklers over stage			
7.			Curtains/scenery treated with flame retardant			
8.			Access to catwalks/elevated stairs controlled			
9.			Fly weights ropes, cables in good repair			
10.			Electrical wiring for stage lights grounded/maintained			
11.			Storage of combustibles limited			
12.			Electrical panels accessible (3-foot clearance)			
13.			Good housekeeping			

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

<b>Section L</b>	<b>Storage</b>					
1.			Storage racks/shelves stable and secure			
2.			Flammables stored in flammable storage cabinet			
3.			Fire extinguisher(s) with current tag			
4.			Electrical panels accessible (3-foot clearance)			
5.			Lawnmowers, etc. kept in outside storage building			
<b>Section M</b>	<b>Maintenance</b>					
1.			Personal protective equipment (safety glasses, earplugs/muffs, etc.) provided and used			
2.			First aid kit provided and maintained			
3.			Material Safety Data Sheets (MSDS) maintained for all chemicals/hazardous materials			
4.			All power tools meet applicable OSHA safety standards			
5.			Signs installed stating, "Removal Of Equipment Guards And Use Of Unguarded Equipment Prohibited"			
6.			All electrical equipment double-insulated or grounded			
7.			Electrical cords/plugs in good repair			
8.			Electrical panels accessible (3-foot clearance)			
9.			Good ventilation provided.			
10.			Housekeeping is adequate			
11.			Safety rules posted			
12.			Flammables kept away from open flame, hot surfaces and electrical exposure			
13.			Only fiberglass or wood ladders used near electrical exposures			
14.			Ladders in good repair			

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

15. Oily rags and mops stored in covered containers.						
16. Compressed gas cylinders properly secured						
<b>Section N</b>						
<b>Building Exterior</b>						
1. Sidewalks in good repair						
2. Parking lots in good repair						
3. Handrails provided on all steps and ramps						
4. Weeds, trees, shrubs, trash adequately controlled						
5. No broken windows						
6. Brickwork in good condition						
7. Exterior electrical outlets GFCI-protected						
<b>Section O</b>						
<b>Security</b>						
1. Employees/volunteers required to complete background forms (forms sent to Conference)						
2. Facility access controlled (fenced and gated)						
3. Key control measures in effect						
4. Facility periodically re-keyed						
5. Floor level windows equipped with locks and screens						
6. Safe combination changed periodically, or after major personnel change						
7. Night watch						
8. Shrubbery trimmed to eliminate shadows/hiding areas						
9. Lighting adequate						
<b>Section P</b>						
<b>Church Monies</b>						
1. Active finance committee meets monthly						
2. Minimal amount of cash kept on premises						
3. Deposits made as soon as possible after monies received						



	Yes	No	Description	Location	Recommendations Made	Date Corrected
4. Routine time and route avoided for depositing funds						
5. Church monies not kept at treasurer's home						
6. Verification of money counts documented by second individual						
<b>Section Q Renting Out Church Facilities</b>						
1. Approval of rent or lease secured from Conference						
2. Rental or lease agreement approved by Conference attorney						
3. Renting/leasing party required to provide certificate of liability insurance naming Conference as additional insured						
<b>Section R Major Contracts</b>						
1. Major contracts negotiated ONLY with specific approval from Conference Office						
<b>Section S Employee Safety</b>						
1. Adult and student employees trained and experienced for tasks/equipment operated, etc.						
2. Training documented						
3. Lockout/tagout policy in place						
4. Chemical/Hazardous Material training provided						
5. Material Safety Data Sheets (MSDS) maintained for all chemicals						
6. Fall protection equipment used per OSHA standards						
<b>Section T Transportation</b>						
1. Scheduled maintenance of owned and non-owned vehicles used in church activities						
2. Vehicle maintenance documented						
3. Vehicles have current registration						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

4. Vehicle use restricted only to official church activities						
5. Keys removed and vehicles locked when not in use						
6. Vehicles with a passenger capacity of 15 or more, and crossing state lines, registered with US Department of Transportation (state laws may vary)						
7. US Department of Transportation # posted prominently in applicable vehicles						
8. Seat belt policy strictly enforced for drivers and passengers						
9. Driver Training for vans with a passenger capacity of 15 or more (state laws may vary); busses; 1-ton trucks or larger; semi truck/trailer rigs						
10. Policy forbidding staff and/or students in back of pickups and/or trucks						
11. Drivers required to adhere to approved routes						
12. Drivers not allowed to carry unauthorized passengers						
13. Drivers complete daily vehicle check-off list						
14. Drivers complete a driver's application form						
15. Drivers at least 21 years of age						
16. Drivers in good health						
17. Driver's license current and suitable for the type of vehicle being driven						
18. No more than two traffic citations during the past three years						
19. No at-fault accidents during the past three years						
<b>Section U</b>						
<b>First Aid</b>						
1. Each activity accompanied by adult supervisors certified in first aid						

	Yes	No	Description	Location	Recommendations Made	Date Corrected
--	-----	----	-------------	----------	----------------------	----------------

2. First aid kits located throughout the church facilities						
<b>Section V</b>			<b>Playgrounds</b>			
1. Supervision present						
2. Equipment and surfaces inspected and maintained						
3. Resilient materials beneath equipment						
4. Adequate separation from equipment						
5. No splinters or projections						
6. Playground complies with Consumer Product Safety Commission guidelines (Download free <i>Handbook for Public Playground Safety</i> at <a href="http://www.cpsc.gov">http://www.cpsc.gov</a> )						
<b>Section W</b>			<b>Activities/Field Trips</b>			
1. Field Trip Pre-Planning (See the Field Trip/Outing Planner at <a href="http://www.adventistrisk.org">www.adventistrisk.org</a> )						
2. Permission Slips obtained						
3. Medical Release Forms available in each vehicle						
4. Each activity accompanied by adult supervisors certified in first aid						
5. Ample supervision provided for all activities						
6. Knowledgeable supervision for each activity						
7. Protective equipment used as required by specific activities						
8. Sports activities require warm up period						