EUSERC

Electric Utility Service Equipment Requirements Committee

Utility: Eugene water & Electric Board
Contact Name: Bob Buchholz
Phone Number: 541-685-7129

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	x				
301A	x				
302			x		
302A			x		
302B	x				
303			x		
304	x				
305	x				
305A	x				
306	x				
307		x			Depth/ Height
308		x			Minimum height
309		x			Minimum height
311	x				
312	x				
313			x		
314			x		
315	x				
316	x				
317		x			Exceeds minimums
318		x			Exceeds minimums
319	x				
320	x				
321	x				
322	x				
323		x			CT Window 5.5 max
324		x			CT Window 5.5 max
325	x				
326	x				
327	x				
328A		x			Exceeds Policy
328B		x			Exceeds Policy
329A		x			Exceeds Policy
329B		x			Exceeds Policy
330	x				
331		x			CT Window 5.5 max
332			x		Remote only
333			x		Remote only
336			x		Remote only
338			x		Case by case
339	x				
342	x				
343		x			Prior approval
343A		x			Prior approval

Drwg	A	C	U	N/A	Explain all "C's"
344			x		
345	x				
347	x				
348		x			Underground preferred
349		x			Prior approval
351		x			Prior approval
353		x			No protrusions pref.
354		x			Class 200 or less
401		x			Utility specific design
404				x	
407		x			Utility provided part #
408			x		Remote only
409			x		Remote only
411		x			Utility specific design
414				x	
416		x			Utility provided part #
418		x			Utility specific design
420				x	
500					
501					
502					
503					
515					
520					
G1		x			
G2	x				
G3	x				
G4	x				
G5		x			Meter height
G6		x			Prior approval
G7		x			Prior approval
G8	x				