Electric Utility Service Equipment Requirements Committee

EUSERC

Utility: Los Angeles Department of Water & Power
Contact Name: David Reusch
Phone Number: 626-333-6491

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	x				
301A	x				
302			x		
302A	x				
302B			x		
303			x		
304	x				
305	x				
305A	x				
306	x				
307	x				
308	x				
309			x		
311	x				
312	x				
313	x				
314	x				
315	x				
316			x		
317			x		
318			x		
319	x				
320	x				
321	x				
322	x				
323			x		
324	x				
325		x			See notes below
326		x			See notes below
327	x				
328A	x				
328B		x			See notes below
329A	x				
329B		x			See notes below
330	x				
331	x				
332	x				
333			x		
336			x		
338			x		
339	x				
342	x				
343	x				
343A			x		

Drwg	A	C	U	N/A	Explain all "C's"
344		x			
345	x				
347		x			See notes below
348		x			See notes below
349		x			See notes below
351			x		
353	x				
354	x				
401		x			See notes below
404				x	
407		x			See notes below
408	x				
409			x		
411	x				
414				x	
416				x	
418				x	
420			x		
500					
501					
502					
503					
515					
520					
G1				x	
G2				x	
G3				x	
G4				x	
G5				x	
G6				x	
G7				x	
G8				x	

NOTES

Drwg		Drwg	
325	Upper & lower flanges limited to 1-1/4"	347	9/16 holes in place of studs not permitted on edgewise term.
326	Upper & lower flanges limited to 1-1/4"	348	Arrangmnts include supply from bus duct and bussed top hats
328B	Mounting base restricted to overhead supply apps	349	Req. one set of terms for ea 400 amps for cust. station apps
329B	Mounting base restricted to overhead supply apps	401	Limited to 5kv services & includes additional notes
		407	Limited to 5kv services & CT info is specific to LADWP