EUSERC

Electric Utility Service Equipment Requirements Committee

Utility: Palo Alto, City of
Contact Name: Jeff Wickstrom
Phone Number: 650-496-6987

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	x				
301A	x				
302	x				
302A		x			See notes below
302B	x				
303			x		
304	x				
305	x				
305A	x				
306	x				
307	x				
308	x				
309	x				
311	x				
312	x				
313	x				
314	x				
315	x				
316	x				
317		x			1 phase only
318	x				
319	x				
320	x				
321			x		
322	x				
323			x		
324	x				
325	x				
326	x				
327	x				
328A	x				
328B	x				
329A	x				
329B	x				
330	x				
331	x				
332	x				
333			x		
336			x		
338			x		
339			x		
342	x				
343			x		
343A			x		

Drwg	A	C	U	N/A	Explain all "C's"
344		x			Prior approval required
345	x				
347	x				
348	x				
349		x			Prior approval required
351	x				
353		x			See notes below
354	x				
401	x				
404			x		
407	x				
408	x				
409		x			Single socket only
411	x				
414			x		
416	x				
418		x			See notes below
420	x				
500					
501					
502					
503					
515					
520					
G1	x				
G2	x				
G3	x				
G4	x				
G5	x				
G6	x				
G7	x				
G8	x				

NOTES

Drwg		Drwg	
302A	Bypasses on 400 Amp services	353	Clearances will be enforced
		418	CPA does not use this configuration