Electric Utility Service Equipment Requirements Committee

EUSERC

Utility: Riverside, City of
Contact Name: Danny Hernandez
Phone Number: 951-351-6383

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301		x			UG instillations only
301A				x	
302			x		
302A	x				
302B		x			Ring-less not accepted
303			x		
304	x				
305	x				
305A	x				
306	x				
307	x				
308		x			
309			x		
311	x				
312	x				
313			x		
314			x		
315		x			350 cable max allowed
316		x			No 3 phase 3 wire
317		x			No 3 phase 3 wire
318		x			Limited use
319		x			No 3 phase 3 wire
320		x			No 3 phase 3 wire
321				x	
322		x			No 3 phase 3 wire
323				x	
324		x			No 3 phase 3 wire
325		x			Meter socket top panel
326		x			Meter socket top panel
327		x			1200 A max
328A		x			No 3 phase 3 wire
328B			x		
329A		x			No 3 phase 3 wire
329B			x		
330	x				
331	x				
332		x			For all service sizes
333			x		
336				x	
338				x	
339		x			Limited use
342	x				
343		x			Contact eng 4 wire sz
343A			x		

Drwg	A	C	U	N/A	Explain all "C's"
344		x			Limited use
345		x			1201a & up, 60" min-
347	x				
348	x				
349		x			No 3 phase 3 wire
351		x			Term. Per Drwg 347
353	x				
354	x				
401		x			Consult engineering
404		x			Depends on field app.
407				x	
408	x				
409				x	
411		x			Consult on 3 wire
414				x	
416				x	
418		x			Depends on app.
420				x	
500		x			
501		x			
502		x			
503		x			
515			x		
520		x			
G1	x				
G2	x				
G3	x				
G4	x				
G5		x			
G6		x			
G7	x				
G8	x				