Electric Utility Service Equipment Requirements Committee

EUSERC

Utility: Seattle City Light
Contact Name: Quan Le/ Vonzell McDowell
Phone Number: 206-684-4259

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301		x			Pre-approval required
301A	x				
302			x		
302A		x			
302B	x				
303				x	
304			x		
305	x				
305A		x			No test blocks
306			x		
307			x		
308		x			Pre-approval required
309		x			Pre-approval required
311		x			100 amp not allowed
312		x			100 amp not allowed
313			x		
314			x		
315			x		
316		x			Hinged cover required
317		x			No 3 phase 3 wire
318		x			Hinged cover required
319		x			No 3 phase 3 wire
320		x			Hinged cover required
321			x		
322		x			No 3 phase 3 wire
323			x		
324		x			No 3 phase 3 wire
325		x			Dwg required in Swgr
326		x			Dwg required in Swgr
327		x			Dwg required in Swgr
328A		x			No 3 phase 3 wire
328B		x			No 3 phase 3 wire
329A		x			No 3 phase 3 wire
329B		x			No 3 phase 3 wire
330	x				
331	x				
332	x				
333				x	
336		x			One socket only, Dwgs
338		x			Consult on remote mtr
339		x			Consult on remote mtr
342	x				
343			x		
343A			x		

Drwg	A	C	U	N/A	Explain all "C's"
344		x			Pre-approval required
345	x				
347	x				
348		x			Pre-approval required
349		x			Pre-approval required
351		x			Pre-approval required
353		x			Pre-approval required
354		x			Pre-approval required
401		x			Pre-approval required
404		x			Pre-approval required
407		x			Pre-approval required
408	x				
409				x	
411				x	
414	x				
416				x	
418				x	
420		x			Pre-approval required
500					
501					
502					
503					
515					
520					
G1		x			No 3 phase 3 wire
G2				x	
G3				x	
G4				x	
G5			x		
G6			x		
G7		x			Pre-approval required
G8	x				