



Electric Utility Service Equipment Requirements Committee

Utility: SCE
Contact Name: Gilbert Aceves
Phone Number: 909-548-7249

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	x				
301A					
302			x		
302A			x		
302B			x		
303			x		
304	x				
305	x				
305A	x				
306	x				
307	x				
308		x			PE recepl req'd for SL
309			x		
311	x				
312	x				
313		x			400 amp limit
314		x			400 amp limit
315	x				
316			x		
317			x		
318			x		
319		x			1P, 3W, 600 amp limit
320	x				
321				x	
322	x				
323			x		
324	x				
325	x				
326	x				
327	x				
328A		x			400 amp limit
328B			x		
329A		x			400 amp limit
329B			x		
330	x				
331	x				
332	x				
333	x				
336			x		
338			x		
339			x		
342	x				
343		x			1200 amp req 4 term
343A			x		

Drwg	A	C	U	N/A	Explain all "C's"
344		x			Limited to 1-3" conduit
345	x				
347	x				
348	x				
349	x				
351			x		
353		x			Added requirements
354	x				
401	x				
404	x				
407	x				
408			x		
409	x				
411	x				
414	x				
416	x				
418	x				
420	x				
500					
501					
502					
503					
515					
520					
G1	x				
G2	x				
G3	x				
G4	x				
G5			x		
G6	x				
G7	x				
G8	x				