EUSERC

Electric Utility Service Equipment Requirements Committee

Utility: Tacoma Public Utilities
Contact Name: Heidi Yates
Phone Number: 253-302-1385

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	X				
301A			X		
302			X		
302A			X		
302B	X				
303			X		
304	X				
305	X				
305A	X				
306	X				
307	X				
308		X			Meter 60" above grade
309		X			Min Cabinet width 30"
311	X				
312	X				
313				X	
314				X	
315				X	
316	X				
317	X				
318	X				
319		X			Up to 800 Amps
320	X				
321	X				
322	X				
323	X				
324	X				
325	X				
326	X				
327	X				
328A	X				
328B	X				
329A	X				
329B	X				
330	X				
331	X				
332	X				
333	X				
336			X		
338			X		
339	X				
342	X				
343				X	
343A				X	

Drwg	A	C	U	N/A	Explain all "C's"
344	X				
345		X			
347		X			Underground
348		X			OH Switchboard
349				X	
351	X				
353	X				
354	X				
401				X	
404				X	
407				X	
408				X	
409				X	
411				X	
414				X	
416				X	
418				X	
420				X	
500					
501					
502					
503					
515					
520					
G1				X	
G2				X	
G3				X	
G4				X	
G5				X	
G6				X	
G7				X	
G8				X	