



Electric Utility Service Equipment Requirements Committee

Utility: Turlock Irrigation District
 Contact Name: Steve Chambers
 Phone Number: 209-883-8517

Place an X in the appropriate box for each drawing: A = Acceptable, C = Consult, U = Unacceptable, N/A = Not Applicable

Drwg	A	C	U	N/A	Explain all "C's"
301	x				
301A	x				
302			x		
302A	x				
302B	x				
303	x				
304	x				
305	x				
305A	x				
306	x				
307		x			See notes below
308	x				
309	x				
311	x				
312	x				
313	x				
314	x				
315		x			Only with TID approval
316	x				
317	x				
318	x				
319	x				
320	x				
321	x				
322	x				
323	x				
324	x				
325	x				
326	x				
327	x				
328A		x			no 3 phase 3 wire
328B		x			no 3 phase 3 wire
329A		x			no 3 phase 3 wire
329B		x			no 3 phase 3 wire
330	x				
331	x				
332	x				
333	x				
336			x		
338			x		
339	x				
342	x				
343	x				
343A		x			See notes below

Drwg	A	C	U	N/A	Explain all "C's"
344			x		
345	x				
347	x				
348	x				
349			x		
351		x			See notes below
353		x			See notes below
354	x				
401	x				
404				x	
407	x				
408	x				
409	x				
411	x				
414				x	
416	x				
418	x				
420	x				
500					
501					
502					
503					
515					
520					
G1		x			Fig. 4 & 5 N/A
G2	x				
G3	x				
G4		x			no 3 phase 3 wire
G5		x			See notes below
G6		x			Only with TID approval
G7		x			Fig. 2 not acceptable
G8	x				

NOTES

Drwg	Description	Drwg	Description
307	Meter height 48 inches, enclosed meters N/A	343A	Requires double set screws
		351	Factory predrilled buss only
		353	36 inch minimum height to meter
		G5	Meter height 48 inch min, 1 socket