

**NOTICE OF INTENT
TO ADOPT MITIGATED NEGATIVE DECLARATION
CASTLEWOOD TANKS REPLACEMENT
ALAMEDA COUNTY PUBLIC WORKS AGENCY**

The project proposes to replace two deteriorating 100,000-gallon redwood water tanks that supply water for domestic consumption and emergency fire control. San Francisco Public Utilities District (SFPUC) supplies water to the CSA. The tanks are part of a gravity based water system situated at an elevation of 895 feet within the Castlewood County Service Area (CSA) Zone 2. The two tanks are approximately 6 feet apart and set back 9-10 feet from the downhill top of slope with approximately 5-foot high retaining walls. The new replacement steel tanks will be located on the same footprint as the existing tanks after demolition. The tank replacement would meet American Water Works Association (AWWA) Section 13-2 seismic standards. The tanks are accessible through private driveway of Castlewood Drive in unincorporated area of Pleasanton.



The Draft Mitigated Negative Declaration (MND) and the initial study upon which it is based are available for review at the Alameda County Public Works Agency Offices 399 Elmhurst Street Hayward, CA 94544 and at the Public Works Agency Website: <https://www.acpwa.org/environmental-documents/>. The document concludes that with proposed avoidance and minimization measures, the project would not result in any significant adverse impacts. If you disagree, please include your reasons with your written comments. The Alameda County Board of Supervisors will consider the MND and all comments received prior to its adoption or approval of the project. Written comments will be accepted during the public review period from August 23 to September 23, 2017. Comments should be emailed to Kwablah@acpwa.org or send by US mail to the address below:

Alameda County Public Works Agency
399 Elmhurst Street
Hayward, CA 94544
Attention: Kwablah Attiogbe