

**PHNA Street Lighting Assessment - August 2014**

<b>Attending</b>	
Organization	Name
PHNA:	E. L. Taylor
	Beth McDonald
City Of Atlanta	Lt. John P. Quigley
	Rick White
Georgia Power:	Richard Gresham

<b>Areas of Concern</b>				
Priority	Location	Owner	Description	Status
High	North Ave @ Freedom Pkwy	City Atl	Freedom Park light pole - light out	Pending
High	Freedom Pkwy between PDL & Ralph McGill	City Atl	Lights appeared to be out on both sides during inspection - Later that night, lights appeared to be working - Needs research	Pending
High	Freedom Pkwy From Highland to Moreland	City Atl	Lights appeared to be out on both sides during inspection - Later that night, lights appeared to be working - Needs research	Pending
Low	North Ave between Freedom Pkwy and Bonaventure - 825 North Ave	City Atl	Take down old light pole	Pending
High	Somerset @ PDL	Ga Power	Light out	Completed
High	PDL @ Greens Liquor	Ga Power	Light out	Completed
High	PDL @ Clermont Hotel	Ga Power	Light out	Completed
High	Bonaventure @ new condos	Ga Power	Light out	Completed
High	Bonaventure @ Dead end	Ga Power	Light out	Pending
High	Barnett behind Moe's	Ga Power	Light out	Completed
High	Seminole - House # 68 - Between North Ave & Freedom Pkwy	Ga Power	Light out	Completed
High	Barnett behind Moe's	PHNA	Get Dept of Planning to determine who owns this area, so that the urban camping issue can be addressed	Pending
High	Freedom Parkway at Seminole - North side of Freedom Parkway behind Babette's	PHNA	Address urban camping issue behind Babette's	Pending

Low	Barnett behind Moe's	PHNA	Need tree trimmed so spot light can reach urban camping area	Pending
Low	Angier Springs @ Somerset	PHNA	Assess if additional lighting is needed after new apartments have been completed	Pending
Low	Somerset from North to PDL	PHNA	Possible tree trimming and/or low lights/porch lights	Pending
Low	Bonaventure	PHNA	Possible tree trimming and/or low lights/porch lights Also need tree trimmed at house #661/667 (half way down)	Pending
Low	Bonaventure @ Dead end	PHNA	Determine owner of unpaved section of Angier Springs (City or Private), and if gate @ AS & Somerset is City or Private	Pending
Low	North Ave between Bonaventure and Freedom Pkwy	PHNA	Possible tree trimming and/or low lights/porch lights	Pending
Low	Cleburne Terrace off Williams Mill near house # 567	PHNA	Request City Of Atlanta to have Ga Power put light on pole	Pending
Low	Corner of North Ave and Seminole	PHNA	Add light on Seminole, or have light at intersection of Seminole @ North turned so that it faces Seminole	Pending
Low	Seminole between Freedom Parkway and North Ave	PHNA	Need tree trimming around the light that's out at house # 68	Pending
Medium	Williams Mill @ Linwood	PHNA	Request City of Atlanta to have a light put on the Ga Power pole that is on the east side - have the light point toward Williams Mill. Also need to trim Pecan tree in Park to allow light from park to shine on street	Pending
Medium	Seminole @ PDL	PHNA	Need a light on the pole already there, and need tree trimmed by the pole with the light on it now	Pending
Medium	Freedom Pkwy Playground off North Ave	PHNA	Need lighting on playground - PHNA to contact Doug Voss at Parks (Parks Director) to determine how to best proceed	Pending

**General Information**

Item Number	Item
1	CPTED - (Crime Prevention Through Environmental Design) Best for specific locations like businesses or apartment complexes. The City of Atlanta is still developing this area, and PHNA should evaluate what areas need this assessment while waiting for the City to finalize training. New developments that are being built should definitely be included in CPTED.
2	Cameras - Best for businesses, apartments, and parking lots. May also be useful in areas where there is a lot of on-street parking. Helpful for evidence gathering. Best use is to install cameras in 'hot spots' that are susceptible.
3	The standard for spacing of street lighting is to have one light on every other pole. Generally lights should not be more than 200 feet apart at a maximum. The preferred distance is 150 feet.
4	Light inspections should be done annually. March is a good month, as it gets dark early and the weather is temperate
5	Lights that are on wooden poles belong to Ga Power. Lights that are on metal poles belong to the City of Atlanta
6	For Georgia Power lights that are out, residents can report these by using the webpage for Georgia Power: <a href="http://www.georgiapower.com/business/outdoor-lighting/report-outage.cshtml">http://www.georgiapower.com/business/outdoor-lighting/report-outage.cshtml</a>
7	Lights that face away from the street are private and are not owned by the City or Ga Power, they are owned by the resident or business
8	To determine the wattage on a street light, look at the housing for the light around the bulb. The number on the housing indicates the wattage. 10 = 100 watts, 15 = 150 watts, and 25 = 250 watts
9	Any lights inside Freedom Park need to be addressed outside of this assessment
10	Many times the issue with inadequate lighting can be due to blockage of the light from trees/foilage, rather than not having enough lights
11	Two option for the neighborhood to consider for areas with inadequate lighting are: 1. Request residents to leave on their porch lights 2. Determine if yard lights along the sidewalk could be installed by residents, and if a discount may be available from a specific vendor
12	The neighborhood should contact City leaders as appropriate to assist with getting the work done
13	For missing street signs, residents should report this by calling 311