

Village of Ruidoso  
313 Cree Meadows Dr.  
Ruidoso, NM 88345

**DATE:** October 12, 2017

**IFB# 2018-004B Well H-1497-POD4 (Green Well) and H-2049-POD2 (Airport 2 Well) Pump Installation**

The following **ADDENDUM #1** shall be incorporated into the Proposal Documents for the above referenced project.

**Question #1-**Will fill material removed from the well need to be removed from the site?

**Answer: Fill material may be spread out in a 2 to 3 inch thick layer in the water containment pit located southeast of the well.**

**Question #2-**What are the specific classifications for personnel working at the site?

**Answer: Contractors shall contact New Mexico Workforce solutions to determine the proper classifications.**

**Question #3-**Are drop-pipe joints at the Airport 2 Well 20 ft or 21 ft long?

**Answer: Joints are 21 ft long. They are currently laid down in 42 ft lengths (2 joints).**

**Question #4-** Can material be discharged to flush pit?

**Answer: Any discharges to the flush pit shall require the Contractor to restore the pit to existing condition or better.**

**Question #5-** How will initial discharge from the Green Well during equipment be configured with respect to existing piping?

**Answer: Initial discharge to verify that the submersible well pump is operating correctly shall be to the discharge pit. Contractor shall provide a meter, valve, and backpressure gage as part of the work.**

**Question #6-** The specifications call for 5.56 OD API casing. The 0.375 in wall is actually a water well casing which would have to be specially thread to 8 round thread and couplings. Available with 8 round threads is a 0.361 wall.

**Answer: 5.56 OD API casing with 8 round thread and couplings in a 0.361 in wall is acceptable..**

The following clarification/adjustments shall be incorporated in the bid documents and included in your bid. Please enter the latest addendum number on the bid page where requested.

Please sign and return by E-Mail ( See Below)

---

Company

---

Signature and Date of receipt of Fax

Phone: 575/257-2721 FAX: 575/257-2628

Email: [Billyrandolph@ruidoso-nm.gov](mailto:Billyrandolph@ruidoso-nm.gov)  
[Sidneythomas@ruidoso-nm.gov](mailto:Sidneythomas@ruidoso-nm.gov)