



SB

## COASTSIDE FIRE PROTECTION DISTRICT

1191 MAIN STREET ■ HALF MOON BAY, CA 94019

TELEPHONE (650) 726-5213  
FAX (650) 726-0132

March 26, 2018

Charles Eadie  
Amerigas C/O Eadie Consultants  
PO Box 1647  
Santa Cruz, CA 95061

Dear Applicant,

After reviewing the planning application to legalize expansion of propane distribution facility at 0 Airport Street, Assessor's Parcel Number 047-300-050 in Princeton (San Mateo County Permit No. PLN2018-00057) I offer the following comments/conditions, which will be applied to this project:

1. Required: Address numbers on contracting background with a minimum 6 inches in height and be visible from the road in the direction of travel.
2. Locked gates shall be provided with a Knox Box or Knox Lock.
3. Provide a 2A10BC fire extinguisher at site protected from the weather.
4. All LPG tanks shall comply with the 2016 CFC Chapter 61 Section 6101 thru 6110 for location, fire protection and usage. Also storage to comply with NFPA Chapter 80.
5. Provide a defensible space around your facility.
6. A fire hydrant with 500 feet that produces 1500 gpm at 20 psi. from a Clow 960.

Our review is not construed as encompassing the structural integrity of the facility nor abrogating more restrictive requirements by other agencies having responsibility. Final acceptance is subject to field inspection and necessary tests.

If you have any questions regarding the above conditions, please call me at 916-943-8112 during normal working hours.

Respectfully,  
John Riddell  
Deputy Fire Marshal  
Coastside Fire Protection District – CAL FIRE

cc: San Mateo County Planning & Building  
File